

Memo No:- **1792**

Date:- **18/08/2026**

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	AMB/04829/8/2026	Sample Details	Date & Time
Sample Classification:	Private	Collected By	VIPIN GUPTA,9896903998
Sender:	PRIME STEPS INTERNATIONAL SCHOOL	Collection Date	13/08/2026 at 13:48
Location :-	, NEAR NEW BUS STAND, SHAHZADPUR, AMBALA	Received at lab	13/08/2026 at 13:53
Latitude :-	77.011495	Tested at Lab	18/08/2026
Longitude :-	30.471927		

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/APHA 9223B-2023/APHA 9221 B & C

Remarks :-

- * The Results Given above are related to the sample as received and tested in AMBALA lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters,the water sample is found "**POTABLE**"



SONIA,CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY ,AMBALA
email:-chemist.ambala@phedharyana.gov.in

-----End of Report-----.